

Table 4-3. Trench dimension schedule.

TRENCH DIMENSION SCHEDULE											
STANDARD TRENCH ITEM NO.	[PIPE SIZES (INCHES)]	A	B ₁	B ₂	C*	D ₁	D ₂	E*	F MIN.	H _w MIN.	W
					6"		6"				
					6"		6"				
					6"		6"				
					6"		6"				

NOTES TO THE DESIGNER:

1. CLEARANCES BASED ON THE THICKEST INSULATION, IF LESS INSULATION (LOWER "k") IS PROVIDED. DIMENSIONS C, D, E AND F WILL BE DIFFERENT THAN SCHEDULED. HOWEVER, OVERALL TRENCH DIMENSIONS SHSALL REMAIN THE SAME. C* & E* DIMENSIONS MUST BE MAINTAINED THROUGHOUT ALL STRAIGHT SECTIONS OF TRENCH TO ALLOW PROPER CLEARANCES FOR EXPANSION.

2. SCHEDULE DESIGNATIONS ARE ASSOCIATED WITH TRENCH DIMENSION SECTION, FIGURE 4-5.

Table 4-4. Expansion Loop Schedule*

Loop Name	Line Sizes	X	Y	YY	Z	ZZ	W	H	U	REMARKS

*See Expansion Loop Detail for Designations (Figure 4-16).

NOTE TO THE DESIGNER:

If only one support is required along parallel leg of loop, ZZ = 0. If only one support is required along perpendicular legs of loop, YY = 0.